Karnataka State Fire & Emergency Services Department
Office of the District Fire Officer
Karnataka State Fire & Emergency Services
VIJAYAPUR Fire Station , VIJAYAPUR-586108
Telephone:08352-270160

DISTRICT FIRE OFFICE
Karnataka Fire and Emergency Services
Takke Road, Vijayapur-586102

C.NO.439/FSCR/DFO/VIJAYAPUR/2026 **Date-08/09/2026**

To,
The President
Vidyaniketan shikshan Samsthe®Sindagi
Vivek International Public School, Vidyaniketan Primary School
& KVSR P.U. College
Vidyapeeth Bandal Road Sindagi
Tq-Sindagi, Dist- Vijayapur

Sir,

Sub:Issue of "***Fire Safety Compliance Report***" to "Vidyaniketan shikshan Samsthe® Sindagi" "Vivek International Public School, Vidyaniketan Primary School & KVSR P.U. College" Situated at Sy No-857/3, Vidyapeeth Bandal Road Sindagi, Tq-Sindagi, Dist- Vijayapur.

Ref:1. NO:GBC(2)2100/2025 Date:03/02/2026
2. Applicants Request Letter Date -24/08/2026
3. C.NO.191/ADV/DFO/VJP/2023 Date-25/11/2023

><><*@*<><

With reference to the subject above cited, the premises of "Vidyaniketan shikshan Samsthe®Sindagi" "Vivek International Public School, Vidyaniketan Primary School & KVSR P.U. College" Situated at Sy No-857/3, Vidyapeeth Bandal Road Sindagi, Tq-Sindagi, Dist- Vijayapur was inspected by The District Fire Officer, Vijayapur on 31/08/2026 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and the details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height)

"GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 &B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the building / premises :-

01.	Name and Address of the Applicant.	:	The President Vidyaniketan shikshan Samsthe®Sindagi Vivek International Public School, Vidyaniketan Primary School & KVSR P.U. College Vidyapeeth Bandal Road Sindagi Tq-Sindagi, Dist- Vijayapur
02.	Name and Address of the premises.	:	Vivek International Public School, Vidyaniketan Primary School & KVSR P.U. College Situated at Sy No-857/3, Vidyapeeth Bandal Road Sindagi, Tq-Sindagi, Dist- Vijayapur
03.	Name and address of the Building owner	:	The President Vidyaniketan shikshan Samsthe®Sindagi Vivek International Public School, Vidyaniketan Primary School & KVSR P.U. College Vidyapeeth Bandal Road Sindagi Tq-Sindagi, Dist- Vijayapur

08/09/26

04.	Number of buildings	:	01 Building.
05.	Number of floors	:	G+1 floors
06.	**Floor-wise details of occupancy:-**		
	Ground floor	:	Class rooms- 08 nos, Principal Room-01no, Office Room-01, Staff Room-01no, Chairman Room-01no.
	1st Floor	:	Class rooms- 08 nos, Science Lab-01no, Computer Room-01, Seminar Hall-01no, Store Room-01no.
07.	Height of the building	:	07.30 mtr
08.	Site area	:	04.20 Acre
09.	Built-up area of each floor:-		
	Ground floor	:	1127.74 Sq.mtr
	1st Floor	:	841.64 Sq.mtr
10.	**Total built-up area**	:	1969.38 Sq.mtr
11.	Surrounding properties:-		
	East	:	Agricultur Land
	West	:	Agricultur Land
	North	:	Agricultur Land
	South	:	06.00 mtr Approach Road
12.	**Set-back area available around the building :-**		
	East	:	Play Ground
	West	:	02.00 mtr
	North	:	08.00 mtr
	South	:	30.00 mtr
13.	Dise code		29031216205, 29031216907

B. On inspection of this Institutional premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)			Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from 06.00 mtr wide road on the Southern side.			-
02	No. of entrances	04 no of Entrance/Exit			-
03.	Width of entry / exit	Width of entry 05.00 mtr & exit width 02.40 mtr			-
04	No. of staircases available	Nos. of staircases	:	02 no's	The staircase must be free from Obstruction all the time.
		Width of staircases	:	01.16 mtr Each	
		Width of treads	:	00.28 mtr Each	
		Height of risers	:	00.15 mtr Each	
		Nos. of riser per flight	:	18 no's Each	
		Height of handrails	:	0.90 mtr Each	
05.	Fire extinguisher	Provided 08 no's of ABC Type Fire extinguishers Each 06.00 Kgs Capacity, & 01 no's of CO2 Type Fire extinguishers Each 04.50 Kgs Capacity.			Complied.
06	Escape routes	Escape route has been marked with luminous light/paint at, ground and First floor directing towards exists and emergency exists .			Complied.

08/09/26

	ire order	Fire safety indicating the details of actions to be taken in case of emergency has been displayed near each staircase landings with the telephone numbers of our Sindagi Fire Station 08488-200201,112 and 101 numbers & telephone numbers of nearest Ambulance Service.	Complied.
08.	Transparent Fire Retardant coat to the electrical panel & Distribution box	Not Done	Recommended to spray Transparent Fire Retardant coat.
09.	No Smoking board	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board has been written in English & Kannada both languages shall be prominently displayed at inside the entry/exit of the each floor.	Complied.
10.	Fire Siren	A Fire Siren has been installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.	Complied.
11.	Nominate One Fire Nodal Officer	1.Shri. Ammogi R Hegganadoddi has been nominated as the nodal officers.	Complied.
12.	Fire fighting training	02 persons have undergone basic Fire fighting training from 07/09/2026 to 08/09/2026 in the premises of The District Fire Office Vijayapura. 1. Shri. Ammogi R Hegganadoddi 2.Shri.NeelammaHegganadoddi	At least 40% of employees shall be trained in basic fire fighting course at our R.A.Mundkur Fire and Emergency Services Training Academy, Bannerghatta Road, Bangalore-29, or Regional training centre hubballi or District Fire Station Vijayapur.
13.	***Fire Precautionary Measures*** *A:- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises.* *B:- Accumulation of combustible waste in and around the premises should be avoided.* *C:- The Exitways shall be always kept clear without any obstruction.* *D:- Liquefied petroleum gas should not be stored in the building.* *E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction.* *F:- During the class hours the class room door shall not be locked from inside to out side.* *G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.*		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing of "**Fire Safety Compliance Report**" **to** "Vidyaniketan shikshan Samsthe®Sindagi" "Vivek International Public School, Vidyaniketan Primary School & KVSR P.U. College" Situated at Sy No-857/3, Vidyapeeth Bandal Road Sindagi, Tq-Sindagi, Dist-Vijayapur. as they have complied all recommendation mentioned above , with the condition of spraying the Transparent Fire Retardant Coat to the electrical panel & Distribution. within 03 months and comply to the undersigned

This "**Fire Safety Compliance Report**" is valid for only one year from the date of issue.

Yours Faithfully

08/09/26

DISTRICT FIRE OFFICER
VIJAYAPUR-586108

ಚಲನ್ ಚಾಲ್ತಿ ಅವಧಿ Challan Validity	ಜಿಲ್ಲೆ District	ಇಲಾಖೆ Department	ಡಿಡಿಓ ಕಚೇರಿ DDO Office
7 Days	VIJAYAPURA	DEPARTMENT OF KARNATAKA FIRE & EMERGENCY SERVICES	DISTRICT FIRE OFFICE, BIJAPUR
ವರ್ಗ Category	ದಿನಾಂಕ Date	ಚಲನ್ ಉಲ್ಲೇಖ ಸಂಖ್ಯೆ Challan Reference Number	ಡಿಡಿಓ ಕೋಡ್ DDO Code
Government	08/09/2026 19:30:00	CR0926007000178335	140120

ಸಂದಾಯದಾರನ ಹೆಸರು Remitter Name	THEPRESIDENT VIDYANIKETANSHIKSHANSAMSTHE SINDAGI	ಮೊಬೈಲ್ ಸಂಖ್ಯೆ Mobile Number	9880170023
ವಿಳಾಸ Address	VIVEK INTERNATIONAL PUBLIC SCHOOL VIDYANIKETAN PRIMARY SCHOOL AND KVSR PU COLLEGE SINDAGI CITY TQ SINDAGI DIST VIJAYAPUR		

ಉದ್ದೇಶ Purpose	ಲೆಕ್ಕ ಶೀರ್ಷಿಕೆ Head of Account	ಉಪ ಉದ್ದೇಶದ ಹೆಸರು Sub Purpose Name	ಉದ್ದೇಶ ನಿರ್ದಿಷ್ಟ ಐಡಿ Purpose Specific ID	ಮೊತ್ತ Amount
COLLECTION OF FEES AND OTHER RECEIPTS FROM FIRE DEPARTMENT	0070~60~109~0~02~000	CLEARANCE CERTIFICATE	Docket No. : APPLICANT REQUEST LETTER	22000.00
ಸಂದಾಯ ಮಾಡುವ ಬ್ಯಾಂಕ್ Remittance Bank	State Bank of India e Pay	ಒಟ್ಟು ಮೊತ್ತ Grand Total		22000.00
		ಒಟ್ಟು ಮೊತ್ತ ಅಕ್ಷರಗಳಲ್ಲಿ Total Amount in Words		Twenty Two Thousand Only

ಪಾವತಿ ವಿವರಗಳು\Payment Details	
ಪಾವತಿ ವಿಧ Payment Mode	Netbanking

*ನಿಮ್ಮ ವಹಿವಾಟನ್ನು ಸಂಸ್ಕರಿಸಲಾಗಿದೆ. ಮುಂದಿನ ಉಲ್ಲೇಖಕ್ಕಾಗಿ ದಯವಿಟ್ಟು ವಹಿವಾಟಿನ ಸಂಖ್ಯೆಯನ್ನು ಬರೆದಿಟ್ಟುಕೊಳ್ಳಿ. ವಹಿವಾಟು ಸಂಖ್ಯೆ

Your Transaction has been processed. Please note the Transaction number for future reference. Transaction No. 9577557792413

*ಕ್ರೆಡಿಟ್ ಕಾರ್ಡ್/ಡೆಬಿಟ್ ಕಾರ್ಡ್ ಮೂಲಕ ಮಾಡಿರುವ ಎಲ್ಲಾ ಪಾವತಿಗಳ ಮೇಲೆ ಹೆಚ್ಚುವರಿ ಸೇವಾ ಶುಲ್ಕ ಅನ್ವಯವಾಗುತ್ತದೆ. ಹಾಗೂ ಬ್ಯಾಂಕ್ ಅದನ್ನು ನೇರವಾಗಿ ಖರ್ಚು ಹಾಕುತ್ತದೆ.

Additional Service charges are applicable for all payments made through CC/DC and the same would be debited directly by the bank.

*ಯಾವುದೇ ಸಂದರ್ಭದಲ್ಲಿ ಸಂದಾಯದಾರನು ಶುಲ್ಕ ಮರುಪಾವತಿಯನ್ನು ಕೊರಬಾರದು

Under no circumstances the remitter will seek a Charge Back

GOVERNMENT OF KARNATAKA

KARNATAKA STATE FIRE AND EMERGENCY SERVICES
DISTRICT FIRE OFFICE VIJAYAPUR
AFZALAPUR TAKKE ROAD, VIJAYAPUR-586108

-------->>>>>>>.<<<<<<<--------

This is to certify that *Shri/Smt.* ***AMMOGI HEGGANADODDI*** ***Vivek International Public School Bandal Road Sindagi Tq:Sindagi Dist:Vijayapur has undergone Basic training in*** *Fire prevention and fire fighting* ***from*** *07-09-2026 to 08-09-2026 [02 days]* ***at District Fire Office Vijayapur Fire Station Premises Vijayapur.***

08/09/26

Date: 08-09-2026
Place: Vijayapur

DISTRICT FIRE OFFICER
Office of the District Fire Office
Vijayapur-586108

C.No:2026-09-616



22

GOVERNMENT OF KARNATAKA

KARNATAKA STATE FIRE AND EMERGENCY SERVICES
DISTRICT FIRE OFFICE VIJAYAPUR
AFZALAPUR TAKKE ROAD, VIJAYAPUR-586108

--------->>>>>>>.<<<<<<<--------

This is to certify that *Shri/Smt.* ***NEELAMMA HEGGANADODDI*** ***Vivek International Public School Bandal Road Sindagi Tq:Sindagi Dist:Vijayapur has undergone Basic training in*** *Fire prevention and fire fighting* ***from*** *07-09-2026 to 08-09-2026 [02 days]* ***at District Fire Office Vijayapur Fire Station Premises Vijayapur.***

08/09/26

Date: 08-09-2026
Place: Vijayapur

DISTRICT FIRE OFFICER
Office of the District Fire Office
Vijayapur-586108

C.No:2026-09-617



23